

# Declaration of performance



No. 12013035

Product type Flush-mounting fire-protection box

Type number 1564-01

Intended place of use Installation box for fire protection compliant  
Closure of openings in fire protection walls

Manufacturer Kaiser GmbH & Co. KG  
Ramsloh 4  
58579 Schalksmühle

System for assessing and inspecting  
the constancy of performance

1

*Notified body with details of their activities in respect of the product type listed above in accordance with European technical assessment*

The notified body of the "Materialprüfanstalt für das Bauwesen Braunschweig" (Materials Testing Institute for Construction Materials Brunswick) has carried out the initial inspection of the factory and the company's own production control in addition to the on-going monitoring, assessment and evaluation of the in-house production control in accordance with System 1, and has issued a certificate of conformity in accordance with the requirements of ETA-18/0418: **Z-6001/048/16**

*Notified body with details of their activities in respect of the product type listed above in accordance with the harmonised standard*

Not relevant

## Declared performance

Class of fire behaviour EI 120 EN 13501-2

Class of fire behavior E EN 13501-1

## *Declaration*

The product described complies with the performance characteristics. The manufacturer bears sole responsibility for the generation of this declaration of performance.

## Miscellaneous:

The product described also complies with the requirements of **Low Voltage Directive 2014/35/EU**. Compliance of this product with the requirements of the guideline is shown by the full adherence to the following standard:

**DIN EN 60670-1: 2005-10**  
**DIN EN 60670-22: 2007-07**

Name and function

Dirk Umbach, Director Market and Innovation Development

Schalksmühle, 05.04.2022

Place and date of issuance

Signature

A handwritten signature in blue ink, appearing to read "Dirk Umbach", written over a horizontal line.