



中国国家强制性产品认证证书



SITIAS
Worldwide Access

证书编号: 2022322313004717

认证委托人名称: 欧葛兰(上海)电气产品贸易有限公司
认证委托人地址: 上海市闵行区合川路 2679 号 9 幢(B 座) 505A 室
生产者名称: AGRO AG
生产者地址: Korbackerweg 7, 5502 Hunzenschwil, Switzerland
生产企业名称: AGRO AG
企业地址: Korbackerweg 7, 5502 Hunzenschwil, Switzerland
产品名称: 电缆接头、缩减/增扩接头、锁紧堵头
系列、规格、型号: Progress *** ***** EX
标准: GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。
产品相关信息详见附件。

发证日期: 2022 年 06 月 30 日

有效期至: 2027 年 06 月 29 日

首次发证日期: 2022 年 06 月 30 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准:

郭新华



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitiias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0006460



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2022322313004717

APPLICANT: AGRO (Shanghai) Electrical Products Trading Co., Ltd.
ADDRESS: Room 505, Building B, Venture International Park, No 2679
Hechuan Road, 201103 Shanghai
MANUFACTURER: AGRO AG
ADDRESS: Korbackerweg 7, 5502 Hunzenschwil, Switzerland
FACTORY: AGRO AG
ADDRESS: Korbackerweg 7, 5502 Hunzenschwil, Switzerland
PRODUCT: Cable gland, Thread adapter, Blanking element
SERIES,SPECIFICATION,MODEL: Progress *** ***** EX
STANDARDS: GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Refer to the attachment for detailed information.

Valid from: June 30, 2022

Valid until: June 29, 2027

Date of original certification: June 30, 2022

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiilas.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0005819



中国国家强制性产品认证证书



证书编号: 2022322313004717

附 件

产品名称: 电缆接头、缩减/增扩接头、锁紧堵头

型号规格: 电缆接头:

Progress MS **** KB EX (M16...M63; Pg9...Pg48; NPT3/8" ...NPT2")

其中, ****可为空白(标准直接头)、

FKN(带防扭曲管直接头)、

T+(带喇叭口直接头)、

W90(90°弯接头);

Progress S2 **** KB EX (M12...M63; Pg7...Pg48; NPT1/4" ...NPT2")

Progress S4 **** KB EX (M12...M63; Pg7...Pg48; NPT1/4" ...NPT2")

其中, ****可为空白(标准直接头);

Progress MS EMV **** KB EX (M16...M63; Pg9...Pg48; each long & short)

其中: ****可为空白(带接触套屏蔽接头)、

Rapid(带接触片屏蔽接头)、

S85(带接触夹头屏蔽接头);

Progress S2 EMV **** KB EX (M16...M63; Pg9...Pg48; each long & short)

Progress S4 EMV **** KB EX (M16...M63; Pg9...Pg48; each long & short)

其中: ****可为空白(带接触套屏蔽接头);

缩减/增扩接头:

MS EX (M16...M63; Pg9...Pg48)

S2 EX (M12...M63; Pg7...Pg48)

S4 EX (M12...M63; Pg7...Pg48)

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2022322313004717

附 件

锁紧堵头:

MS EX, S2 EX, S4 EX (M8...M63; Pg7...Pg48)

电缆接头:

Progress MS EMV easyCONNECT KB EX (M16...M63; Pg9...Pg48; NPT3/8" ...NPT2")

Progress S2 EMV easyCONNECT KB EX (M12...M63; Pg7...Pg48; NPT1/4" ...NPT2")

Progress S4 EMV easyCONNECT KB EX (M12...M63; Pg7...Pg48; NPT1/4" ...NPT2")

防爆标志:

Ex eb IIC Gb、Ex tb IIIC Db

电气参数:

/

相关报告编号:

2022S17402-007192

使用条件:

1. 产品使用工作温度范围: $-60^{\circ}\text{C} \sim +100^{\circ}\text{C}$ 。
2. 外壳防护等级 IP66/IP68。

批 准:



上海仪器仪表自控系统检验测试所有限公司